

Cayuga County Water and Sewer Authority

7413 County House Road, Auburn, NY 13021

Telephone: (315) 252-0920

Fax:(315) 515-3026

Spring 2011

Dear Water Customer:

Enclosed please find your copy of the City of Auburn's 2010 Annual Water Quality Report. This report is fairly self-explanatory. However, if you have any questions regarding the report or the data, please call me.

By law we must provide every customer of the Authority an Annual Water Quality Report. The City of Auburn is our provider of potable water and the annual report is based on their treatment and testing of the water that is supplied to the Authority for distribution.

We continue to do monthly coliform tests and all samples tested satisfactory. We have also tested for lead and copper at required locations. The City of Auburn also samples for all the above. Please review the information provided.

Aurelius Water District 1A

Contaminant	Violation	Sample Date	Result	Units	MCL	MCLG	Sources in Drinking Water
Lead	No	2009	AL = < .001 Range <0.001	ug/L	AL= 0.015	0	Corrosion of household plumbing systems; Erosion of natural deposits.
Copper	No	2009	AL = 0.056 Range 0.028-0.1	mg/L	AL= 1.3	1.3	Corrosion of household plumbing systems; Erosion of natural deposits; leaching from wood preservatives.

Respectfully submitted,

J. Wilson
Senior Clerk

Enc.